

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 39830
 Permit No. _____
 Basin 87

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 20943

1. OWNER Nevada Top Structures ADDRESS AT WELL LOCATION Beatty Ranch
 MAILING ADDRESS P.O. Box 11363 Reno NV 89520

2. LOCATION S.F. 1/4 Sec 15 T 18 N/S R 20 E Washoe County
 PERMIT NO. 516 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Log

6. LITHOLOGIC LOG M for 29

Material	Water Strata	From	To	Thick-ness
<u>Sandy Silty clay</u>	<u>Yes</u>	<u>0</u>	<u>12.0</u>	<u>12.0</u>
<u>Sandy Silty clay</u>	<u>Yes</u>	<u>12.0</u>	<u>18.0</u>	<u>6.0</u>
<u>Silty Sand</u>	<u>Yes</u>	<u>18.0</u>	<u>22.0</u>	<u>4.0</u>
<u>Clayey Silty Sand</u>	<u>Yes</u>	<u>22.0</u>	<u>32.0</u>	<u>10.0</u>
<u>Sandy clay</u>	<u>Yes</u>	<u>32.0</u>	<u>41.5</u>	<u>9.5</u>

8. WELL CONSTRUCTION
 Depth Drilled 41.5 Feet Depth Cased 41.5 Feet

HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 0 Feet 41.5 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>5.6 40</u>	<u>PVC</u>	<u>0</u>	<u>41.5</u>

Perforations:
 Type perforation Factory slot
 Size perforation 0.20

From _____ feet to _____ feet
 From 10 feet to 41.5 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 8 feet
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 8 feet to 41.5 feet

9. WATER LEVEL
 Static water level 5.8 feet below land surface
 Artesian flow NA G.P.M. NA P.S.I.
 Water temperature Cold °F Quality NA

Date started 10/10 1992
 Date completed 10/20 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>NA</u>	<u>NA</u>	<u>NA</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Anderson Drilling Contractor
 Address 1635 Belford RD, RENO NV, 89509 Contractor

Nevada contractor's license number 34525 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028

Signed Paul Anderson
 By driller performing actual drilling on site or contractor
 Date 10/20/92