

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19114

1. OWNER Ross de Lipkau ADDRESS AT WELL LOCATION Masonic Memorial Gardens
MAILING ADDRESS P.O. Box 2790 Reno, Nevada 89505 Reno, Nevada
2. LOCATION N 1/2 SW 10 T 19 R 19 Washoe County
PERMIT NO. 16844 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. ~~Landscaping~~ PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fill Dirt		0	1	1
Clay/cobbles		1	10	9
Sandy Clay		10	20	10
Sand/Boulders		20	60	40
Loose Boulders		60	65	5
Pea Gravel/Boulders		65	90	25
Red Clay / Boulders				
Gravel	X	90	140	50
Course Gravel	X	140	185	45
Sandy Clay		185	195	10
Sand / Gravel	X	195	215	20
Gravel/Clay/Boulders	X	215	258	43
Clay		258	280	22
Sandy Clay		280	300	20
Sand/Gravel/Pea Gravel	X	300	330	30
Clay / Sand		330	360	30
Course Sand/P Grav/Clay	X	360	384	24
Sandy Clay		384	390	6
Sand/Pea Gravel 10% clay	X	390	420	30

8. WELL CONSTRUCTION
Depth Drilled 420 Feet Depth Cased 412 Feet
HOLE DIAMETER (BIT SIZE)
From 12 1/4 Inches To 0 Feet 420 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Fect)	To (Feet)
8 5/8	22.36	.250	+2	98

Perforations: Double Row Mill
Type perforation 1/8 X 3
Size perforation 1/8 X 3
From 98 feet to 412 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 420 feet

Date started 12-25 1992
Date completed 12-1 1992

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
300		air on rig

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow - G.P.M. - P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling and Pump Co Contractor
Address P.O. Box 590 Contractor
Winnemucca, Nevada 89446-0590
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713
Signed Roy L. Wilson
By driller performing actual drilling on site or contractor
Date 12-2-92