

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19944

1. OWNER Granite Construction ADDRESS AT WELL LOCATION 590 yds. South
 MAILING ADDRESS 1900 Glendale Robbchive - Interchange I - 80
Sparks, Nevada 89432 Reno, Nevada
 2. LOCATION SW 1/4 NE 1/4 Sec. 18 T. 19 N. S. R. 19 E. Washoe County
 PERMIT NO. C 121 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. Const.. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Clay		0	2	2
Cobbles / Clay		2	25	23
Green / Brown Clay		25	45	20
Sandy Clay		45	55	10
Yellow Chalk / Clay		55	60	5
Red / Green Clay		60	100	40
Sandy Clay (lost Circulation)		100	115	15
White Chalk		115	120	5
Sandy Clay hard		120	230	110
sand (lost circ)				
Brown Sandy Shale		230	245	15
Blue Clay		245	260	15
Brown Clay		260	380	120
(no Circulation Void)		380	390	10
Blue Clay / Sand		390	400	10
Gray Clay/Shale		400	500	100
Siltstone		500	800	300

8. WELL CONSTRUCTION
 Depth Drilled 800 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)
 From To
14 Inches 0 Feet 500 Feet
9 7/8 Inches 500 Feet 800 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 3/4</u>	<u>28.04</u>	<u>.250</u>	<u>+2</u>	<u>170</u>

Perforations:
 Type perforation Double Perf / Louvered
 Size perforation 1/8 X 3
 From 170 feet to 240 feet
 From 240 feet to 350 feet Louvered
 From 350 feet to 500 feet
 From _____ feet to _____ feet
 From 500 feet to 800 OPEN feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 500 feet

Date started 11-11, 19 92
 Date completed 11-25, 19 92

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>air on rig</u>	

9. WATER LEVEL
 Static water level Unknown feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling and Pump Co. Contractor
 Address P.O. Box 590 Contractor
Winnemucca, Nevada 89446-0590
 Nevada contractor's license number 015234
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1713
 Division of Water Resources, the on-site driller.
 Signed Roy Wilson
 Driller performing actual drilling on site or contractor
 Date 12-2-92