

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21742

1. OWNER Michael Gullihur ADDRESS AT WELL LOCATION _____
4655 Alder 590 Dog Valley Rd
 MAILING ADDRESS _____
Reno, Nv 89502 Lot 4 Block C

2. LOCATION NW 1/4 SE 1/4 Sec. 7 T. 19 N/S R. 18 E. Washoe County
 PERMIT NO. 38-293-04 - Sunrise Creek # 2
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Loose dirt & rock		0	18	18
Gravel & loose dirt		18	37	19
Truckee formation		37	90	53
Green volcanic rock & clay stone		90	128	38
Green & black volcanic rock		128	299	171
T.D. 299 ft				

8. WELL CONSTRUCTION
 Depth Drilled 299 Feet Depth Cased 299 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0	100
8 1/2 Inches	100	299

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 1	299

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3

From 259 feet to 279 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 100 feet to 299 feet

9. WATER LEVEL
 Static water level 68 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 10/27/92, 19_____
 Date completed 10/28/92, 19_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		1

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc
Contractor
 Address 625 Spice Islands Dr Suite L
Contractor
Sparks, Nv 89431

Nevada contractor's license number 15291
 issued by the State Contractor's Board

Nevada driller's license number issued by the 1132
 Division of Water Resources, the on-site driller

Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 11/3/92