

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21739

1. OWNER Perry Smith / Dave Keil ADDRESS AT WELL LOCATION 10145 Osage Court
 MAILING ADDRESS 10735 Whitehawk 10145 Osage Court
Reno, Nv 89506 Lot C Parcel 2 of Map 2616
 2. LOCATION NE 1/4 SE 1/4 Sec 25 T 21 N/S R18 E Washoe County
 PERMIT NO. 86-350-43 Silver Knolls Subdivision Name
Issued by Water Resources Parcel No.

3. WORK PERFORMED New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay		0	10	10
D.G. sands & brown clay		10	30	20
Brown clay		30	70	40
Green clay		70	90	20
D.G. & brown clay		90	100	10
D.G. & sand		100	145	45
D.G. & tan clay		145	159	14
Case to 159 ft T.D.				
Bottom 20 ft blank				
is filled with gravel and sand				

8. WELL CONSTRUCTION
 Depth Drilled 159 Feet Depth Cascd 159 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
11 Inches 0 Feet 50 Feet
8 3/4 Inches 50 Feet 159 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+ 1</u>	<u>159</u>

Perforations:
 Type perforation factory
 Size perforation 3/ 32 X 3
 From 119 feet to 139 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 159 feet

9. WATER LEVEL
 Static water level 40 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Address 625 Spice Islands Dr Suite L
Sparks, Nv 89431
 Nevada contractor's license number issued by the State Contractor's Board 15291
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1132
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 10/16/92

Date started 10/7/92, 19_____
 Date completed 10/8/92, 19_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>17</u>		<u>1</u>