WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39050
Permit No.
Basin 92A

NOTICE OF INTENT NO. 20550

1. OWNER David Gushen
MAILING ADDRESS 4175 W. 4th St. #4
Reno, NV. 89503

ADDRESS AT WELL LOCATION David Gushen
Lot #9 Coldsprings Way
Reno, NV. 89506

2. LOCATION NW ¼ NE ¼ Sec. 19 T 21N N/S R 19E E Washoe County
PERMIT NO. Issued by Water Resources | Parcel No. 087-041-04 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	1
Brown Clay w/some		1	31	30
boulder and Gravels				
Sandy Brown Clay		31	45	14
Brown Clay		45	110	65
Soft Zone	X	110	114	4
Brown Clay		114	149	35
Soft Zone	X	149	152	3
Brown Clay w/ granite		152	185	33
sands				
Soft Zone	X	185	191	6
Brown Clay		191	200	9

Date started November 24, 1992, 19
Date completed November 25, 1992, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NO TEST			

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	200 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	200

Perforations: Factory Sawed Slot
Type perforation
Size perforation 3/32 x 3 x 5 around
From 115 feet to 125 feet
From 145 feet to 155 feet
From 175 feet to 195 feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured

Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 85 feet below land surface
Artesian flow 35 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling Inc.
Contractor
Address P.O. Box 12370
Contractor
Reno, NV. 89510

Nevada contractor's license number issued by the State Contractor's Board 22549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [signature]
By driller performing actual drilling on site or contractor
Date November 30, 1992

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627