

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21406

1. OWNER Chris Lacey ADDRESS AT WELL LOCATION Hungry Valley  
 MAILING ADDRESS 410 Mustang Crt.  
Reno, NV. 89502  
 2. LOCATION SW 1/4 SE 1/4 Sec 24 T 21N N/S R 19E E. Washoe County  
 PERMIT NO. 080-710-60 Hungry Valley Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	3	3
Brown Clay & some D.G.		3	18	15
Gray Granite		18	40	22
Soft Zone (NO WATER)		40	41	1
Gray Granite		41	119	78
Soft Zone (NO WATER)		119	122	3
Gray Granite		122	189	67
Soft Zone (NO WATER)		189	191	2
Gray Granite		191	256	65
Soft Zone (NO WATER)		256	261	5
Gray Granite		261	287	26
Fracture (APP 2 GPM)		287	288	1
Gray Granite		288	293	5
Fracture (NO WATER)		293	294	1
Gray Granite		294	320	26
Fracture Granite		320	339	19
Gray Granite		339	350	11

8. WELL CONSTRUCTION  
 Depth Drilled 350 Feet Depth Cased 350' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
8 5/8 Inches 50 Feet 350 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>0</u>	<u>350</u>

Perforations: Factory sawed slot  
 Type perforation \_\_\_\_\_  
 Size perforation 3/32 x 3 x 5 around  
 From 305 feet to 345 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 \_\_\_\_\_  
 Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 350 feet

9. WATER LEVEL  
 Static water level 280 feet below land surface  
 Artesian flow 25 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling Inc. Contractor  
 Address P.O. BOX 12370  
Reno, NV. 89510 Contractor  
 Nevada contractor's license number 22549  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 923  
 Division of Water Resources, the on-site driller:  
 Signed Wayne Drilling Inc.  
 driller performing actual drilling on site or contractor  
 Date December 8, 1992

Date started November 30, 1992, 19\_\_\_\_\_  
 Date completed December 2, 1992, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>NO TEST</u>			