WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39872
Permit No.
Basin 49

NOTICE OF INTENT NO. 10039

1. OWNER JAKE Reed po Box
MAILING ADDRESS 226 Elko NV 89801
ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ NW ¼ Sec. 2 T. 33 N/S R. 54 Ⓔ Elko County
PERMIT NO. 020604 #6213 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loam		0	8	8
Gravel	water	8	14	6
Red Rock		14	30	16
Gravel	water	30	33	3
Red Rock		33	38	5
Red SAND STONE		38	151	113
Gravel	water	151	154½	3.5
Brown CLAY		154.5	172	17.5
Gravel	water	172	173	1
Brown CLAY		173	180	7
Gravel	water	180	181	1
Brown CLAY		181	186	5
Gravel	X	186	192	6
Red CLAY		192	213	21
~~Gravel~~ Gravel	X	213	227	14
Red Rock		227	234	7
~~Gravel~~ Gravel	X	234	260	26

Date started 9-30, 1992
Date completed 10-16, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Ap 300	135	12

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
15" Inches	0 Feet	260 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10		250	+2	260

Perforations:
Type perforation Slots
Size perforation 3/16 x 3"
From 120 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 105
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 105 feet to 260 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fenting Drilling Co (Contractor)
Address PO Box 525 (Contractor)
Elko N.V. 89803
Nevada contractor's license number issued by the State Contractor's Board 31904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11-14-92

(Rev. 3-91)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627