WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39911
Permit No.
Basin 87

NOTICE OF INTENT NO. 21627

1. OWNER Simon Hydro-Search
MAILING ADDRESS 5250 South Virginia Suite#280
Reno, NV 89502

ADDRESS AT WELL LOCATION Santa Fe Pacific Pipeline
Beggin Way
Sparks, NV.

2. LOCATION SE ¼ NE ¼ Sec. 9 T. 19N N/S R. 20 E. Washoe County
PERMIT NO. M/O 396C MW 212 (Issued by Water Resources) | Parcel No. | Sparks (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Asphalt | | 0 | 6" | 6" |
| Gravel | | 6" | 9.75" | 9.25" |
| Gravelly SAnd | | 9.75 | 11.75 | 2' |
| Sandy Gravel | | 11.75 | 17 | 5.25 |
| Gravelly Sand | | 17 | 21.5 | 4.5 |
| Sandy Gravel | | 21.5 | 40 | 18.5 |
| Gravelly Sand | | 40 | 50 | 10 |
| Sandy Gravel | | 50 | 59 | 9' |

Date started October 29 1992, 19
Date completed October 30 1992, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| NO TEST | | | |

8. WELL CONSTRUCTION
Depth Drilled 59 Feet Depth Cased 59 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 9 5/16 Inches | | 0 Feet | 59 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 5 | | Sch 80 | 0 | 59 |

Perforations:
Type perforation Factory Sawed Slot
Size perforation 60 Slot
From 18.4 feet to 59 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 9.4
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 9.4 feet to 59 feet

9. WATER LEVEL
Static water level 31 feet below land surface
Artesian flow Not Known G.P.M. P.S.I.
Water temperature NK °F Quality NK

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV. 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed [signature] (By driller performing actual drilling on site or contractor)
Date November 30, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627