WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 34912
Permit No.
Basin 87

NOTICE OF INTENT NO. 21653

1. OWNER Simon Hydro-Search
MAILING ADDRESS 5250 South Virginia Suite 280
Reno, NV. 89502

ADDRESS AT WELL LOCATION Santa Fe Pacific Pipeline
Deming Way
Sparks, NV

2. LOCATION NW ¼ SE ¼ Sec. 10 T 19 N X N/S R 20 E Washoe County
PERMIT NO. M/O 396C (MW 213) Issued by Water Resources | Parcel No. | Sparks Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	3"	3"
Fill		3	2'9"	2'6"
Clay		2'9"	5.5'	2'9"
Silt		5.5'	9'	3.5'
Sandy Clayey Silt		9'	13'	4'
Sandy Silt		13'	17'	4'
Sandy Gravel and Cobbles		17'	40'	23'
Sand		40'	44'	4'

Date started November 2 1992, 19
Date completed November 3 1992, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NO TEST			

8. WELL CONSTRUCTION
Depth Drilled 44 Feet Depth Cased 41.5 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 5/16 Inches		0 Feet	44 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5		Sch 80	0	11

Perforations:
Type perforation Machine Slot
Size perforation 60 Slot
From 11 feet to 41.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 6'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 6 feet to 41.5' feet

9. WATER LEVEL
Static water level 24 feet below land surface
Artesian flow Not Known G.P.M. P.S.I.
Water temperature NK °F Quality NK

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling Inc. Contractor
Address P.O. Box 12370 Contractor
Reno, NV. 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed [signature] By driller performing actual drilling on site or contractor
Date November 30, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627