WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39946
Permit No.
Basin 91

NOTICE OF INTENT NO. 20002

1. ~~OWNER~~ Consultant: Summit Engineering Corporation
MAILING ADDRESS 5405 Mae Anne AVe.
Reno, NV. 89523

Client: Boomtown Hotel & Casino
~~ADDRESS AT WELL LOCATION~~ I-80 & Garson Rd.
Well# 15 Reno, NV.

2. LOCATION ¼ So ¼ Sec. 16 T. 19 N/S R. 18 E. Washoe County

PERMIT NO. M/O - 504B (Issued by Water Resources) | 381-200-09 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown, Silty Sand minor clay, dry		0	30	30
Dark Brown, Clayey sand, minor gravel, dry		30	35	5
Dark Brown to Grey sandy boulder gravel dry, minor clay		35	60	25

Date started 9/29/92, 19
Date completed 9/29/92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
~~No Test~~			

8. WELL CONSTRUCTION
Depth Drilled 60 Feet Depth Cased 40/60 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 5/16 Inches	0 Feet	60 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Sch 40	0	12
2		Sch 40	0	40

Perforations:
Type perforation Machine Slotted
Size perforation 0.125 inch
From 12 feet to 37 feet
From 40 feet to 60 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 9'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 11/39 feet to 38/60 feet

9. WATER LEVEL
Static water level N/A feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV. 89510
Nevada contractor's license number 22549 issued by the State Contractor's Board
Nevada driller's license number 908 issued by the Division of Water Resources, the on-site driller
Signed Gary C. Hedman
By driller performing actual drilling on site or contractor
Date October 26, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627