

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF PERMIT NO. 20002  
Boomtoun Hotel & Casino

1. Consultant: Summit Engineering Corporation Client: \_\_\_\_\_  
 1. OWNER Summit Engineering Corporation ADDRESS AT WELL LOCATION: Boomtoun Hotel & Casino  
 MAILING ADDRESS: 5405 Mae Anne Ave. 1-80 & Garson Rd.  
Reno, NV. 89523 Well#2 Reno, NV.

2. LOCATION: 1/4 SO 1/4 Sec 16 T 19 N/S R 18 E Washoe County  
 PERMIT NO. M/O 504-B 381-200-09 Subdivision Name \_\_\_\_\_  
Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BlackBrown, Clayey Sand, dry		0	20	20
Black-Grey, Silty Sand, minor clay		20	40	20
Brown, Gravelly Sand fine to coarse grained sand, angular gravel to 1" diameter		40	50	10
Brown, Sandy Gravel fine to coarse grained sand, gravel to 1 inch diameter		50	60	10

8. WELL CONSTRUCTION  
 Depth Drilled 60 Feet Depth Cased 40/60 Feet

SOLE DIAMETER (BIT SIZE)  
9 5/16 From 0 To 60  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Sch 40	0	12
2		Sch 40	0	40

Perforations:  
 Type perforation Machine Slotted  
 Size perforation 0.125 inch  
 From 12 feet to 37 feet  
 From 40 feet to 60 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 9'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 11/39 feet to 38/60 feet

9. WATER LEVEL  
 Static water level N/A feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 9/28/92, 19\_\_\_\_\_  
 Date completed 9/28/92, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
No Test			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling Inc. Contractor  
 Address P.O. Box 12370 Contractor  
Reno, NV. 89510

Nevada contractor's license number 22549  
 issued by the State Contractor's Board

Nevada driller's license number issued by the 908  
 Division of Water Resources, the on-site driller

Signed [Signature]  
 Date October 26, 1992