WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39975
Permit No.
Basin 101

NOTICE OF INTENT NO. 21423

1. OWNER Giovanette Construction
MAILING ADDRESS 5767 Reno Highway, Fallon, NV 89406
ADDRESS AT WELL LOCATION 5767 Reno Highway, Fallon, NV 89406

2. LOCATION NW ¼ NE ¼ Sec. 29 T 19 N/S R 27 E Churchill County
PERMIT NO. (Issued by Water Resources) Parcel No. 08-571-79 Giovanette (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand | | 0 | 14 | 14 |
| Brown Clay | | 14 | 19 | 5 |
| Brown Coarse Sand | | 19 | 29 | 10 |
| Fine Brown Sand | | 29 | 33 | 4 |
| Brown Coarse Sand | | 33 | 44 | 11 |
| Brown Fine Sand | | 44 | 46 | 2 |
| Green Fine Sand | | 46 | 58 | 12 |
| Fine Brown Sand | | 58 | 64 | 6 |
| Coarse Brown Sand | X | 64 | 82 | 18 |

Date started November 5, 19 92
Date completed November 5, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 82 Feet Depth Cased 82 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 Inches | 0 Feet | 82 Feet | |
| Inches | Feet | Feet | |
| Inches | Feet | Feet | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.92 | .188 | 0 | 82 |
| | | | | |
| | | | | |

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 78 feet to 81 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 82 feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. BOX 1265 (Contractor)
Fallon, NV 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
Signed Doug Parsons (By driller performing actual drilling on site or contractor)
Date Nov 10, 1992.

STATE ENGINEER '92 NOV 13 AM 10:35

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627