

OFFICE USE ONLY  
 Log No. 39976  
 Permit No. \_\_\_\_\_  
 Basin 101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21432

1. OWNER Max Archer ADDRESS AT WELL LOCATION 1155 Clyde Court  
 MAILING ADDRESS 1155 Clyde Court Fallon, NV 89406  
 2. LOCATION NE 1/4 SE 1/4 Sec 22 T 19 N/S R 28 E Churchill County  
 PERMIT NO. 010-211-13 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	7	7
Brown Coarse Sand		7	28	21
Fine Brown Sand		28	32	4
Brown Coarse Sand		32	40	8
Fine Green Sand		40	43	3
Black & Green Coarse Sand		43	46	3
Fine Green Sand		46	51	5
Black & Green Coarse Sand		51	58	7
Fine Green Sand		58	64	6
Black & Green Coarse Sand		64	69	5
Fine Gray Sand		69	74	5
Brown & Black Coarse Sand		74	81	7
Fine Gray Sand		81	83	2
Brown Coarse Sand	X	83	101	18

8. WELL CONSTRUCTION  
 Depth Drilled 102 Feet Depth Cased 102 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 102 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	103

Perforations:  
 Type perforation Mill Cut  
 Size perforation \_\_\_\_\_  
 From 98 feet to 101 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 102 feet

Date started November 17, 19 92  
 Date completed November 17, 19 92

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailers <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
		<u>26:30</u>	<u>26</u>

9. WATER LEVEL  
 Static water level 21' 3" feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Parsons Drilling, Inc. Contractor  
 Address P.O. Box 1265 Contractor  
Fallon, NV 89407  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715  
 Signed Douglas Parsons  
 \_\_\_\_\_ driller performing actual drilling on site or contractor  
 Date Nov 18, 1992