

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22266

1. OWNER PETE BEEKOFF ADDRESS AT WELL LOCATION 1368
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE, NV

2. LOCATION SW 1/4 NE 1/4 Sec 5 T 12 N R 21 E DOUGLAS County
 PERMIT NO. 35-140-13 FISH SPRINGS Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other...MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	8	8
COARSE SAND		8	17	9
COARSE SAND w/ GRAVEL	✓	17	41	24
GRAVEL w/ CLAY		41	48	7
CLAY		48	52	4
CLAY w/ GRAVEL		52	76	24
COARSE SAND		76	80	4
SANDY CLAY w/ GRAVEL		80	103	23
CLAY		103	108	5
SANDY CLAY w/ GRAVEL	✓	108	160	52

92 NOV 30 P2:51 RECEIVED STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 X 3/32
 From 120 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 28 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC. Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
 Signed Pat J. Moore
 By driller performing actual drilling on site or contractor
 Date 10/26/92

Date started 10/22, 1992
 Date completed 10/26, 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25 +</u>	<u>—</u>	<u>1</u>