

OFFICE USE ONLY  
 Log No. 39986  
 Permit No. \_\_\_\_\_  
 Basin 105

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 22211

1. OWNER Marshall Bartels ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS PO Box 536 LOCATION 1708 Foothill rd.  
Minden, NV 89423 Minden NV  
 2. LOCATION NW 1/4 NW 1/4 Sec 27 T 13 N/S R. 19 E County Boyd  
 PERMIT NO. 17-180-02 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
top soil SAND (DG)		0	20	
SAND (DG)	X	20	30	
SAND & SOME CLAYS		30	65	
SAND & ROCKS		65	75	
SAND		75	125	
Fine sand		125	145	
SAND & ROCK		145	155	
SANDS		155	200	

8. WELL CONSTRUCTION

Diameter 10 inches Total depth 200 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches

Casing record \_\_\_\_\_  
 Weight per foot 125 lbs Thickness .188

Diameter	From	To
<u>6.5</u> inches	<u>0</u> feet	<u>200</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type cement grout  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 200 feet to 50 feet

Perforations:  
 Type perforation Factory Perf  
 Size perforation 3" x 5/16"  
 From 200 feet to 180 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 10-10-92, 1992  
 Date completed 10-10, 1992

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>1400</u>	<u>30+</u>		<u>2 hrs.</u>
_____	_____	_____	_____
_____	_____	_____	_____

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL

Static water level 25 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lauchek Drilling Inc  
 Address 2608 Keller Minden NV  
 Nevada contractor's license number issued by the State Contractor's Board #021268  
 Nevada contractor's driller's number issued by the Division of Water Resources #1380  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1495  
 Signed Michael Allen  
 By driller performing actual drilling on site or contractor  
 Date 10-12-92