WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39987
Permit No.
Basin 105

NOTICE OF INTENT NO. 22214

1. OWNER MIKE RANDALL
MAILING ADDRESS 1321 Yellow Jacket Gard. NV. 89423
ADDRESS AT WELL LOCATION 1716 Douglas Ct. Minden NV

2. LOCATION NE ¼ SW ¼ Sec. 2 T. 13 N/S R. 20 E. Douglas County
PERMIT NO. NW SE (Issued by Water Resources) 23-090-63 (Parcel No.) Johnson In. (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	35	
CLAY & SAND		35	45	
CLAY		45	70	
CLAY & SAND		70	125	
CLAY SAND & GRAVEL		125	150	
SAND & GRAVEL		150	170	
CLAY SAND & GRAVEL	X	170	185	
CLAY & SAND		185	245	
CLAY		245	260	
CLAY & SAND		260	280	
CLAYS		280	320	

Date started 11-17, 1992
Date completed 11-25, 1992

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailer	20 gpm	—	3 hrs

8. WELL CONSTRUCTION
Depth Drilled 320 Feet Depth Cased 320 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 7/8 Inches		0 Feet	320 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.5 lbs	.188	0	320

Perforations:
Type perforation Factory cut
Size perforation 3" x 5/32"
From 300 feet to 320 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 320 feet to 50 feet

9. WATER LEVEL
Static water level 171 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Rainchuck Drilling Inc. (Contractor)
Address 2668 Teller Minden NV (Contractor)

Nevada contractor's license number issued by the State Contractor's Board #021268
Nevada driller's license number issued by the Division of Water Resources, the on-site driller #495
Signed Michael [illegible] (By driller performing actual drilling on site of contractor)
Date 11-30-92

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O) 627