

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22217

1. OWNER Fernando Ralera ADDRESS AT WELL LOCATION 1598 Saratoga Ct  
 MAILING ADDRESS 4 Sunnydaks Dr  
San Rafael Calif 94903  
 2. LOCATION NW 1/4 SE 1/4 Sec 27 T 17 N/S R 20 E Douglas County  
 PERMIT NO. 21-153-36 Issued by Water Resources Parcel No. \_\_\_\_\_  
Johnson / High Point Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	20	
SAND & GRAVEL		20	30	
SAND		30	70	
SAND & GRAVEL		70	75	
SAND		75	130	
SAND & GRAVEL		130	140	
SAND & SILTS	<input checked="" type="checkbox"/>	140	200	
SAND & GRAVEL	<input checked="" type="checkbox"/>	200	245	
SAND & CLAY	<input checked="" type="checkbox"/>	245	300	

8. WELL CONSTRUCTION  
 Depth Drilled 305 Feet Depth Cased 300 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 9 7/8 Inches To 0 Feet 305 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Pt. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>0</u>	<u>300</u>

Perforations:  
 Type perforation Indefinite  
 Size perforation 3" X 5 1/2"  
 From 300 feet to 280 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 300 feet to 50 feet

9. WATER LEVEL  
 Static water level 151 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 11-11, 1992  
 Date completed 11-16, 1992

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Bailer</u>	<u>20gpm</u>	<u>-</u>	<u>2 hrs.</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Franchise Drilling Inc.  
 Address 268 Fuller Millers Nu  
 Nevada contractor's license number issued by the State Contractor's Board #02268  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1495  
 Signed Michael Allen  
 By driller performing actual drilling on site or contractor  
 Date 11-18-92