

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20500

1. OWNER Sam Lompa ADDRESS AT WELL LOCATION 24 Serravallo Cutoff
 MAILING ADDRESS 2200 E Fifth St. Carson City Wheaton Nev 89444
 2. LOCATION NE 1/4 NW 1/4 Sec. 12 T. 10 N/S R. 23 E. Lyon County
 PERMIT NO. none Issued by Water Resources Parcel No. 10-671-07 Subdivision Name none

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	6"	
LGT BRN SANDY CLAY		6"	3'	
DK BRN SANDY CLAY		3	6	
LGT BRN SANDY CLAY		6	18	
MED-CRS. SAND/BRN CLAY		18	23	
SANDY BRN CLAY W/SM GRAVEL		23	58	
MED-CRS SAND W CLAY	✓	58	67	
SANDY BRN CLAY	✓	67	73	
SM GRAVEL W/SH CLAY STRKS	WB	73	114	
DK GRN SANDY CLAY		714	125	

92 DEC -3 AM 54

STATE ENGINEER

8. WELL CONSTRUCTION
 Depth Drilled 125 Feet Depth Cased 125 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 12 1/2 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"		188	0	125

Perforations:
 Type perforation FACTORY
 Size perforation 3/32 x 3'
 From 99 feet to 119 feet
 From 119 feet to 125 TRUCK BIT feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 125 feet

9. WATER LEVEL
 Static water level 35 feet below land surface
 Artesian flow _____ G.P.M. 30+ P.S.I.
 Water temperature WARM °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Edmund Miller Contractor
 Address Box 92 Smiths Nev. 89430 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 32166
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
 Signed Edmund Miller
 By driller performing actual drilling on site of contractor
 Date 11-30-92

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30+</u>		

Date started Nov 20, 1992
 Date completed Nov 23, 1992