

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20501

1. OWNER Harry Everett ADDRESS AT WELL LOCATION No 3 Circle Drive Wellington
 MAILING ADDRESS No 3 Circle Drive Wellington Nev 89444
 2. LOCATION SW 1/4 SE 1/4 Sec 27 T 11 N/S R 23 E Syon County
 PERMIT NO. none Issued by Water Resources Parcel No. 10-331-06 Subdivision Name none

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>almond D-D & rock</u>		<u>0</u>	<u>80</u>	<u>80</u>
<u>brown clay</u>		<u>80</u>	<u>95</u>	<u>15</u>
<u>coarse sand gravel & rock</u>	<input checked="" type="checkbox"/>	<u>95</u>	<u>190</u>	<u>95</u>

8. WELL CONSTRUCTION
 Depth Drilled 190 Feet Depth Cased 180 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 Inches 0 Feet 100 Feet
8 Inches 100 Feet 190 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8"</u>		<u>188</u>	<u>0</u>	<u>180</u>

Perforations:
 Type perforation Heavy sand slott
 Size perforation 3/32 x 3 in
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 90 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality good

Date started Oct 27, 1992
 Date completed Nov 5, 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30+</u>	<u>95</u>	<u>6</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Edmund Miller Contractor
 Address Box 92 Smiths Pt Contractor
89430
 Nevada contractor's license number issued by the State Contractor's Board 32166
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
 Signed Edmund Miller
 By driller performing actual drilling on site or contractor
 Date 10-30-92