

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20499

1. OWNER John Von Seeburg ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS 2317 DONNA MARIN CT SANTA ROSA, CA 42 Rangeland Drive  
2. LOCATION NW 1/4 SW 1/4 Sec. 7 T. 11 N/S R. 24 E County \_\_\_\_\_  
PERMIT NO. 9-081-01 Parcel No. \_\_\_\_\_ Subdivision Name River View Lyon  
Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>TOP SOIL</u>		<u>0</u>	<u>1 1/2</u>	
<u>SANDY BRN CLAY</u>		<u>1 1/2</u>	<u>15</u>	
<u>COURSE TO FINE SAND</u>		<u>15</u>	<u>19</u>	
<u>SANDY BRN CLAY</u>		<u>19</u>	<u>33</u>	
<u>COURSE TO FINE SAND</u>		<u>33</u>	<u>37</u>	
<u>SANDY BRN CLAY</u>		<u>37</u>	<u>48</u>	
<u>COURSE TO FINE SAND</u>		<u>48</u>	<u>59</u>	
<u>SM GRAVELS w/ CLAY STRKS</u>		<u>59</u>	<u>70</u>	
<u>COURSE SAND w/ SHT CLAY STRKS</u>		<u>70</u>	<u>93</u>	
<u>SM GRAVELS w/ GREY CL. STRKS</u>		<u>93</u>	<u>120</u>	
<u>SANDY GREY CLAY w/ URSE SAND</u>		<u>120</u>	<u>180</u>	
<u>SM GRAVELS TO FINE SAND GREY CLAY</u>		<u>180</u>	<u>230</u>	
<u>SM GRAVELS SAND w/ BRN CLAY</u>		<u>230</u>	<u>260</u>	

8. WELL CONSTRUCTION  
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)  
From 12 1/4 Inches To 260 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8"</u>		<u>188</u>	<u>0</u>	<u>260</u>

Perforations:  
Type perforation FACTORY SLOT  
Size perforation 3/32" x 3"  
From 240 feet to 260 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
Depth of Seal 50  Cement Grout  
Placement Method:  Pumped  Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 50 feet to 260 feet

9. WATER LEVEL  
Static water level 170 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. 30+ P.S.I.  
Water temperature COLD °F Quality GOOD

Date started 11/13, 1992  
Date completed 11/17, 1992

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30+</u>		

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ED MILLER Contractor  
Address BOX 92 Contractor  
SMITH, NV 89447 89430  
Nevada contractor's license number issued by the State Contractor's Board 32166  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 718  
Signed Edmund Miller  
By driller performing actual drilling on site or contractor  
Date Nov 18 1992