

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20555

1. OWNER Ron Vucovich ADDRESS AT WELL LOCATION 175 Del Masa Dr. Reno, NV 89511  
 MAILING ADDRESS 14205 Prairie Reno, NV 89511

2. LOCATION NW 1/4 NW 1/4 Sec. 9 T. 17N N/S R. 20E E. Washoe County  
 PERMIT NO. 017-350-19 Parcel No. Stream boat area Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

| Material                     | Water Strata | From | To  | Thick-ness |
|------------------------------|--------------|------|-----|------------|
| Brn ClayStky                 |              | 0    | 5   | 5          |
| Tan Clay Sandy               |              | 5    | 28  | 23         |
| Gray Clay Sandy              |              | 28   | 41  | 13         |
| Brn Clay                     |              | 41   | 63  | 22         |
| Gray Rock Broken& Fractured  |              | 63   | 76  | 13         |
| Gray Rock w/ Sft. Stks. X    | X            | 76   | 122 | 46         |
| Gray Rock Soft Zone X        | X            | 122  | 125 | 3          |
| Gray Rock Broken&Fractured X | X            | 125  | 171 | 36         |
| Gray Rock Harder             |              | 171  | 180 | 9          |

8. WELL CONSTRUCTION  
 Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
8 5/8 Inches 50 Feet 180 Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 5/8              |                     | .188                    | 0           | 180       |

Perforations:  
 Type perforation Factory Sawn Slot  
 Size perforation 3/32 x 3 x 5 around

From 135 feet to 175 feet  
 From 175 feet to 180 feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Placement Method:  Pumped  
 Poured

Gravel Packed:  Yes  No  
 From 50 feet to 180 feet

9. WATER LEVEL  
 Static water level 70' feet below land surface  
 Artesian flow 20+ G.P.M. P.S.I.  
 Water temperature warm °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling Inc. Contractor  
 Address P.O. Box 12370 Contractor  
Reno, NV. 89510

Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908

Signed Wayne Drilling Inc.  
 By driller performing actual drilling on site or contractor  
 Date December 22, 1992

Date started December 16, 1992, 19  
 Date completed December 18, 1992, 19

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

|         | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---------|--------|-------------------------------|--------------|
| NO TEST |        |                               |              |

'92 DEC 24 AM 11:01  
 RECEIVED  
 STATE ENGINEERS OFFICE