WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40017
Permit No.
Basin 87

NOTICE OF INTENT NO. 20553

1. OWNER Jarold & Brian Ellison
MAILING ADDRESS 740 Glen Vista Dr.
Sparks, NV 89434

ADDRESS AT WELL LOCATION 12535 Westridge
Reno, NV. 89511

2. LOCATION SW ¼ SE ¼ Sec. 18 T. 18N N/S R. 20E E. Washoe County
PERMIT NO. (Issued by Water Resources) 44-082-05 (Parcel No.) SW Reno (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Brown Clay, Boulders, Gravels		2	66	64
Soft Zone		66	69	3
Brown Clay, smaller boulders, & gravels		69	111	42
Brown sandy clay		111	168	57
Soft Zone	X	168	189	21
Brown Sandy clay		189	200	11

Date started December 8, 1992, 19
Date completed December 9, 1992, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NO TEST			

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	Feet	0 Feet	100 Feet
8 5/8 Inches	Feet	100 Feet	200 Feet
Inches	Feet	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	200

Perforations:
Type perforation Factory Sawed Slot
Size perforation 3/32 x 3 x 5 around
From 165 feet to 195 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 200 feet

9. WATER LEVEL
Static water level 150 feet below land surface
Artesian flow 20 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV. 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date December 15, 1992

'92 DEC 24 A11:00
STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627