WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40018
Permit No.
Basin 102

NOTICE OF INTENT NO. 10005

1. OWNER Jake Huber
MAILING ADDRESS PO. Box 279 Verdi NV 89439
ADDRESS AT WELL LOCATION Ramsey Cut off of Highway 50 Lot #1

2. LOCATION SW ¼ SW ¼ Sec. 35 T. 18 N/S R. 24 E. Lyon County
PERMIT NO. NA Issued by Water Resources | 15-211-22 Parcel No. | Tanaya - Lunos Subdivision Name
LOT NO. 1

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dirt & Gravel		0	17	17
Brown & Black Shale		17'	28	
Red Clay and Shale Mixed		28	37	
Brown Shale		37	61	
Gray Shale		61	183	
Hard Blk shale		183	230	
Hard Blk shale with quartz Mixed		230	260	
Broken Shaley & white quartz		260	270	
Fault at 260' to 270' Water Bearing				

Date started Oct, 24, 1992
Date completed Nov, 11, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100	250	3 Hrs

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11" Inches	0 Feet	60' Feet
8 3/4 Inches	60' Feet	270' Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
~~188~~	~~13.00~~			
6 5/8	13.00	188	+1	270'

Perforations:
Type perforation Torch Cut
Size perforation 1/8 x 6"
From ____ feet to ____ feet
From 250' feet to 270' feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60' feet to 270' feet

9. WATER LEVEL
Static water level 140' feet below land surface
Artesian flow NA G.P.M. ____ P.S.I.
Water temperature ____ °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling INC Contractor
Address PO. Box 599 Silver Springs 89429 Contractor
1095 Pueblo St.
Nevada contractor's license number issued by the State Contractor's Board 31841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1240
Signed Nathaniel L. Leach
By driller performing actual drilling on site or contractor
Date Nov 12/92

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(D1-627)