WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40019
Permit No.
Basin 101

NOTICE OF INTENT NO. 21457

1. OWNER Ed Allen
MAILING ADDRESS 1265 Wood Drive, Fallon, NV 89406
ADDRESS AT WELL LOCATION 1265 Wood Drive, Fallon, NV 89406

2. LOCATION SE ¼ SW ¼ Sec. 31 T. 18 N/S R. 29 E. churchill County
PERMIT NO. (Issued by Water Resources) Parcel No. 7-831-11 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	16	16
Brown Clay		16	23	7
Brown COarse Sand		23	31	8
Black & Green Coarse				
Sand		31	38	7
Black Clay		38	59	21
Black COarse Sand		59	65	6
Green Clay		65	71	6
Black & Green Coarse				
Sand		71	82	11
Gray Sandy Clay		82	84	2
Black & Green Coarse				
Sand		84	91	7
Gray Sandy Clay		91	98	7
Brown Sandy Clay		98	131	33
Brown Coarse Sand	X	131	142	11

Date started December 9, 19 92
Date completed December 9, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 142 Feet Depth Cased 142 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	142 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	142

Perforations:
Type perforation Mill Cut
Size perforation 178"
From 138 feet to 141 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 142 feet

9. WATER LEVEL
Static water level 13' 4" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
Signed Doug Parsons (By driller performing actual drilling on site or contractor)
Date Dec 16, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627