

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19981

1. Consultant: Simon Hydro-Search Client: _____
 OWNER _____ ADDRESS AT WELL LOCATION Washoe Keystone Fuel
 MAILING ADDRESS: 5250 S. Virginia Suite #280 Fourth Street
Reno, NV. 89502 Reno, NV.
 2. LOCATION NE $\frac{1}{4}$ SE $\frac{1}{4}$ Sec. 10 T. 19 N. N/S R. 19 E. Washoe County
 PERMIT NO. M/O 288A MW-7 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition Domestic
 Deepen Abandon Other _____ Municipal/Industrial Monitor Stock

4. PROPOSED USE
 Irrigation Test Cable Rotary RVC
 Air Other/Tubex _____

5. WELL TYPE

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy clay, coarse grnd sand, non plastic clay, cobbles, gravel(20%). up to $\frac{1}{2}$ ' dia., subrnd to subanglar		0	3	3'
Silty sand, fn to coarse grnd, well sorted, loose 50% silt and fn grnd sand 10% gravel & cobbles, int minor clay		3	9	6'
Silty sandy clay, 10-20% silt & fn grnd sand, plastic clay, soft, damp slt hyd		9	16	7'
Sand, 5-10% fn grnd, med to coarse sand, well sted		16	28	12'
Boulders, granite, cobbles minor sand,		28	29	1'
1 st water @ 29'				
Int. well sorted coarse grnd sand		29	39	10'

8. WELL CONSTRUCTION
 Depth Drilled 39 Feet Depth Cased 39 Feet

HOLE DIAMETER (BIT SIZE)
 From To
7 $\frac{1}{4}$ " Inches 0 Feet 39 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		Sch 40 PVC	0	14

Perforations:
 Type perforation Factory sawed slot
 Size perforation .020
 From _____ feet to _____ feet
 From 14 feet to 49 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 1.2' Bentonite Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 25 feet to 39 feet

9. WATER LEVEL
 Static water level Not Known feet below land surface
 Artesian flow Not Known G.P.M. _____ P.S.I.
 Water temperature 64 °F Quality PH 7.0 *EC=660umhos/km

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling Inc.
 Contractor
 Address P.O. Box 12370
Reno, NV. 89510
 Contractor

Nevada contractor's license number 22549
 issued by the State Contractor's Board

Nevada driller's license number issued by the 908
 Division of Water Resources, the on-site driller

Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date December 15, 1992

Date started May 19, 1992, 19____
 Date completed May 19, 1992, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

TEST METHOD	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NO TEST			

STATE ENGINEER
 10101
 26
 27
 28
 29
 30
 31
 32
 33
 34
 35
 36