

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19982

Consultant: Simon Hydro-Search  
 1. OWNER- 5250 S. Virginia Suite # 280  
 MAILING ADDRESS: Reno, NV. 89502

Client: Washoe Keystone Fuel  
 ADDRESS AT WELL LOCATION: 4th Street  
 Reno, NV.

2. LOCATION NE 1/4 SE 1/4 Sec. 10 T. 19N N/S R. 19 E Washoe #17 County  
 PERMIT NO. M/O 288A IW-1  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Tubex \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay, sand, cobbles		0	3	3'
Sandy Clay, stiff, plastic, 10-20 med to coarse sand, minor gravel grains up to 1/4" damp		3	13	10'
As above with gravel		13	17	4'
Med to coarse sand, As above w/ grn size up to 1"		17	19	2'
As above w/ cobbles up to 4" subrndd		19	30	11'
Boulders w/ 10-20% sand 5-10% soft clay		30	31	1'
As above No Clay		31	40	9'
Inc sand(70-80%) coarse grn, well sorted		40	46	6'
		46	49	3'

8. WELL CONSTRUCTION  
 Depth Drilled 49 Feet Depth Cased 49 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 9 5/16 Inches To 0 Feet 49 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		Sch 40 PVC	0	25

Perforations:  
 Type perforation Factory Sawn Slot x 2  
 Size perforation .064  
 From 25 feet to 49 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 1ft. Bentonite 3.5ft  Neat Cement  
 Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 25 feet to 49 feet

9. WATER LEVEL  
 Static water level Not Known feet below land surface  
 Artesian flow Not Known G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 71 °F Quality PH 6.5 \*FC=430uhmos/ km

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling Inc.  
 Address P.O. Box 12370  
Reno, NV. 89510  
 Nevada contractor's license number 22549  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 908  
 Division of Water Resources, the on-site driller.  
 Signed [Signature]  
 by driller performing actual drilling on site or contractor  
 Date December 14, 1992

Date started May 21, 1992, 19\_\_\_\_  
 Date completed May 21, 1992, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
NO TEST			

DEC 24 11:01  
 RECEIVED  
 STATE ENGINEERS OFFICE