

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19982

1. Consultant: Simon Hydro-Search Client: \_\_\_\_\_  
 MAILING ADDRESS: 5250 S. Virginia Suite # 280 ADDRESS AT WELL LOCATION: Washoe Keystone Fuel  
Reno, NV. 89502 Fourth Street  
Reno, NV.  
 2. LOCATION: NE 1/4 SE 1/4 Sec. 10 T. 19N N/S R. 19 E Washoe County  
 PERMIT NO. M/O 288A IW-2 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Tubex

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill Material		0	3	3'
Clay&Cobbles(up to 4") stiff plastic, sandy (10YR 3/2) coarse grn sand, 5-10% cobbles		3	16	13'
Gravel & cobbles & clay		16	18	2'
As above w/10-20%Clay		18	20	2'
Gravel & cobbles, no clay		20	23	3'
V.coarse sand & gravel well sorted, minor fines intermittent stiff plastic clay		23	29	6'
Cobbles & gravel w/ 20% v. coarse sand 1st water		29	39	10'
As above w/ inc sand		39	43	4'
Boulders, gravel, sand, crse grn		43	48	5'
As above w/ inc sand		48	49	1'

8. WELL CONSTRUCTION  
 Depth Drilled 49' Feet Depth Cased 49' Feet

HOLE DIAMETER (BIT SIZE)  
 From 0 To 49  
9 5/16 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		Sch 40 PVC	0	25

Perforations:  
 Type perforation Factory Sawed Slot x 2  
 Size perforation .064  
 From 25 feet to 49 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 1ft Bentonite 3'ft  Neat Cement  
 Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 25 feet to 49 feet

9. WATER LEVEL  
 Static water level Not Known feet below land surface  
 Artesian flow Not Known G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 79 °F Quality PH 6.6 \*EC=490 uhmhos/km

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling Inc.  
 Address P.O. Box 12370  
Reno, NV. 89510  
 Nevada contractor's license number 22549  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 908  
 Division of Water Resources, the on-site driller  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date December 14, 1992

Date started May 26, 1992, 19\_\_\_\_  
 Date completed May 26, 1992, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NO TEST			

DEC 24 11 02 AM '92  
 RECEIVED  
 STATE ENGINEERS