

OFFICE USE ONLY
 Log No. 40031
 Permit No. _____
 Basin. 25

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21793

1. OWNER Carlos Romo ADDRESS AT WELL LOCATION 20 Verda Rose Ln
 MAILING ADDRESS 35 Chatham Ct
San Jose, Ca 95139

2. LOCATION SE 1/4 SE 1/4 Sec 19 T 21 N/S R 21 Washoe County
 PERMIT NO. 076-371-05 Spanish Springs Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Over burden & volcanic rock		0	3	3
Volcanic rock		3	30	27
Brown clay		30	70	40
Brown clay with some volcanic rock		70	115	45
Mostly volcanic rock little brown clay		115	245	130
volcanic rock & reddish brown clay		245	280	35
Hard volcanic rock red green black		280	340	60
Fractured green brown volcanic rock		340	375	35
Soft red volcanic rock		375	390	15
Brown clay & multi-colored volcanic rock	X	390	410	20
Brown clay		410	418	8
T.D. 418 ft				

8. WELL CONSTRUCTION
 Depth Drilled 418 Feet Depth Cased 418 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 7/8 Inches	0	50
8 1/2 Inches	50	418

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 2	418

Perforations:
 Type perforation factory
 Size perforation 3/32 3

From 377 feet to 397 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50
 Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 50 feet to 418 feet

9. WATER LEVEL
 Static water level 210 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc Contractor
 Address 625 Spice Islands Dr Suite L Contractor
Sparks, Nv 89431

Nevada contractor's license number 15291
 issued by the State Contractor's Board

Nevada driller's license number issued by the 1132
 Division of Water Resources, the On-site driller

Signed Roger M Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall President 12/11/92

Date started 12/3/92, 19_____
 Date completed 12/5/92, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		1