


PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17955



1. OWNER INDEPENDANCE MINING CO., INC. ADDRESS AT WELL LOCATION JERRITT CANYON MINE SITE  
 MAILING ADDRESS MOUNTAIN CITY STAR ROUTE  
ELKO, NV 89801

2. LOCATION NE 1/4 NW 1/4 Sec 33 T 41 N/R 53 E ELKO County \_\_\_\_\_  
 PERMIT NO WAIVER #M/O-408-B N/A Parcel No. \_\_\_\_\_ N/A Subdivision Name \_\_\_\_\_  
Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY, SAND & GRAVEL		0	55	55
<i>Updated lithology 1/11/92</i>				
<i>Gravelly Clay</i>		0	10	10
<i>Sand &amp; Clay, some Gravel</i>		10	13	3
<i>Sandy Clay</i>		13	20	7
<i>Gravelly Clay</i>		20	23	3
<i>Clay, sand &amp; Gravel</i>	X	23	31	8
<i>Clayey Sand</i>		31	35	4
<i>Clay, sand &amp; Gravel</i>		35	43	8
<i>Sand &amp; Gravel</i>		43	46	3
<i>Clay, sand &amp; Gravel</i>		46	55	9

8. WELL CONSTRUCTION  
 Depth Drilled 55 Feet Depth Cased 50 Feet

HOLE DIAMETER (BIT SIZE)  
 From 9 Inches To 0 Feet 55 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	PVC	SCH 40	0	20

Perforations:  
 Type perforation SLOT  
 Size perforation .020  
 From 20 feet to 50 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 17  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 17 feet to 55 feet

9. WATER LEVEL  
 Static water level 23 feet below land surface  
 Artesian flow N/A G.P.M. N/A P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started DECEMBER 15, 1992  
 Date completed DECEMBER 15, 1992

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name LANG EXPLORATORY DRILLING Contractor  
 Address 2286 WEST 1500 SOUTH Contractor  
SALT LAKE CITY, UT 84104  
 Nevada contractor's license number issued by the State Contractor's Board 0021976  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1488  
 Signed Scott Lang  
By driller performing actual drilling on site or contractor  
 Date DECEMBER 16, 1992