

OFFICE USE ONLY
 Log No. 40046
 Permit No. 1057
 Basin 1057

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27413

1. OWNER Bob Carlson ADDRESS AT WELL LOCATION Archie Circle
 MAILING ADDRESS P.O. Box 100 Carson City NV. 89702
 2. LOCATION NE 1/4 NE 1/4 Sec 9 T. 12 N. R. 20 E Douglas County
 PERMIT NO. 27-704-06 Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RYC
 Air Other Mid

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Overburden sand, gravels</u>		<u>0'</u>	<u>7'</u>	<u>7'</u>
<u>Small gravels w/ sand</u>		<u>7'</u>	<u>69'</u>	<u>62'</u>
<u>Pea gravels + sand</u>		<u>69'</u>	<u>97'</u>	<u>28'</u>
<u>Course sand 3/4 to 1' gravels w/ water</u>		<u>97'</u>	<u>140'</u>	<u>43'</u>

8. WELL CONSTRUCTION
 Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)
 From 1 1/4 Inches To 0 Feet 140' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.203</u>	<u>0'</u>	<u>140'</u>

Perforations:
 Type perforation Mill slot
 Size perforation 3/2 x 3/32
 From _____ feet to _____ feet
 From 120' feet to 140' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 100'
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 100' feet to 140' feet

9. WATER LEVEL
 Static water level 35' feet below land surface
 Artesian flow _____ G.P.M. 257 P.S.I.
 Water temperature Cold F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A & H PUMP CO.
 Address 5551 Hwy. 50 East #3 Carson City, Nevada 89701
703-0459 - 883-4022

Nevada contractor's license number 31839
 issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535

Signature [Signature]
 By driller performing actual drilling on site or contractor

Date 11-30-92

Date started 11-12 1992
 Date completed 11-23 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>257</u>	<u>8'</u>	<u>2 Hr.</u>

RECEIVED
 JAN 13 1993
 STATE ENGINEER'S OFFICE