WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40048
Permit No.
Basin 105

NOTICE OF INTENT NO. 22415

1. OWNER Dr. Kirk White
MAILING ADDRESS 15
ADDRESS AT WELL LOCATION 956 Blue Bird Rd. Gardnerville Nv.

2. LOCATION NW ¼ NE ¼ Sec 16 T. 12 N/S R. 21 E. Douglas County
PERMIT NO. (Issued by Water Resources) 35-320-04 (Parcel No.) APN 1221-15-000-014 (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Small Cobbles		0	15	15
Hard Sand		15	35	20
¼ gravels		35	40	5
Firm Light Brown Clay		40	75	35
¼ to ½" gravels		75	105	30
Brown Clay w/ Small Gravels		105	160	55
Gumney Brown Clay		160	230	70
Firm Brown Clay w/small gravels		230	285	55
Firm Blue Clay		285	390	105
Blue Clay w/ Small gravels		390	405	15
Good Water Zone Broken gravels	xxx	405	450	45

Date started 12-6, 1992
Date completed 12-8, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12+	40'	4 hrs.

8. WELL CONSTRUCTION
Depth Drilled 450 Feet Depth Cased 450' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
11½	0	55'
10	55	450'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13.03	.188	0	450

Perforations:
Type perforation Mill Slot
Size perforation 3/4" X 3/32
From ... feet to ... feet
From 410' feet to 450' feet
From ... feet to ... feet
From ... feet to ... feet
From ... feet to ... feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55' feet to 450' feet

9. WATER LEVEL
Static water level 320' feet below land surface
Artesian flow ... G.P.M. 12+ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name
Contractor A & H PUMP CO.
Address 5551 Hwy. 50 East
Carson City, Nevada 897
883-0459 - 883-4
885-1889
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joe Butts
By driller performing actual drilling on site or contractor
Date 12/18/92

STATE ENGINEER'S
JAN 13 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627