

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18974

1. OWNER BLAINE MCGUIRE ADDRESS AT WELL LOCATION 3625 CLARK DRIVE WASHOE  
 MAILING ADDRESS 3625 CLARK DRIVE WASHOE  
 2. LOCATION NE 1/4 NW 1/4 Sec. 4 T. 16N N/S R. 20 E WASHOE County  
 PERMIT NO. 4616 Parcel No. 50-422-12 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	2	
SANDY BRN CLAY		2	9	
LIGHT BRN SAND		9	20	
GRAY SANDY CLAY		20	23	
FINE-MED CRS SAND		23	40	
GRAY SANDY CLAY		40	48	
GRAY SAND & DG	WB	48	70	
GRAY SANDY CLAY		70	76	
GRAY SAND & DG	WB	76	103	
MULTI COLOR GRAY GRN		103	117	
GRAY SAND & DG w/CLAY STRKS WB		117	140	

8. WELL CONSTRUCTION  
 Depth Drilled 140' Feet Depth Cased 140' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet  
140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		1.88	0	140

Perforations:  
 Type perforation FACTORY  
 Size perforation 3/32 X 3"  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 100  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 100 feet to 140 feet

9. WATER LEVEL  
 Static water level 24' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 25+ P.S.I.  
 Water temperature 50.0 °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A & H PUMP Contractor  
 Address 5551 Hiway 50 E #3 Contractor  
CARSON CITY, NV 89701  
 Nevada contractor's license number 93475-31839  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1535  
 Division of Water Resources, the on-site driller.  
 Signed Jerald W. McNeill  
 By driller performing actual drilling on site or contractor  
 Date 1-9-93

Date started 1 5 93, 19\_\_\_\_  
 Date completed 1 9 93, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25+</u>		

**RECEIVED**  
**JAN 13 1993**  
 STATE ENGINEER'S OFFICE