

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21748

1. OWNER Pat Varnum ADDRESS AT WELL LOCATION 289 Surrey Ct
 MAILING ADDRESS 20 Sunbeam Parcel B
Reno, Nv 89511

2. LOCATION SW 1/4 SE 1/4 Sec 7 T. 17 N/S R. 20 E Washoe County
 PERMIT NO. 45-310-69 - Pleasant Valley
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Cobbles & boulders & brown dirt		0	10	10
Cobbles & boulders volcanic		10	20	10
Mixture of volcanic & decomposed granite cobbles & boulders		20	50	30
Volcanic cobbles & boulders & coarse sands & little brown tan clay		50	60	10
Volcanic cobbles & boulders & coarse sands		60	120	60
T.D. 120 feet				

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 120 Feet
 10 5/8 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 1	120

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 90 feet to 110 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 60 Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 60 feet to 120 feet

RECEIVED
JAN 04 1993
 STATE ENGINEER'S OFFICE

Date started 12/8/92 19____
 Date completed 12/9/92 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		1

9. WATER LEVEL
 Static water level 45 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
Contractor
 Address 625 Spice Islands Dr Suite L
Contractor
Sparks, Nv 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1132
 Division of Water Resources, the on-site driller.
 Signed Roger M Thrall
By driller performing actual drilling on site or contractor
 Date 12/10/92 Roger M. Thrall