WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48059
Permit No.
Basin 83

NOTICE OF INTENT NO. 21792

1. OWNER Mary Zuccarini
MAILING ADDRESS 970 York Way
Sparks, Nv 89434

ADDRESS AT WELL LOCATION
2321 Empire Rd
Lot 102 Block G

2. LOCATION NW ¼ SW ¼ Sec. 33 T 18 N/S R 21 E Storey County
PERMIT NO. (Issued by Water Resources) 03-045-26 (Parcel No.) Virginia City Highlands (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[XX] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	3	3
Volcanic rock & dirt		3	45	42
Tan clay & volcanic rock purple white spec		45	60	15
Volcanic rock multi color - mostly purple white spec		60	95	35
Purple volcanic rock blue gray clay & volcanic rock		95	335	240
Gray & little gray rock volcanic		335	385	50
Blue gray clay & volcanic rock		385	399	14
T.D. 399 ft				

RECEIVED
JAN 12 1993
STATE ENGINEER'S OFFICE

Date started 12/14/92, 19
Date completed 12/16/92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		1

8. WELL CONSTRUCTION
Depth Drilled 399 Feet Depth Cased 399 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10 5/8	0	50
8 ½	50	399

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 1	399

Perforations:
Type perforation 3/32 X 3 factory
Size perforation 3/32 X 3
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [XX] Yes [ ] No
Depth of Seal 100+
Placement Method: [ ] Pumped [XX] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [XX] Yes [ ] No
From 100 feet to 399 feet

9. WATER LEVEL
Static water level 220 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc (Contractor)
Address 625 Spice Islands Dr Suite L Sparks (Contractor)
Sparks, Nv 89431
Nevada contractor's license number issued by the State Contractor's Board 15291
Nevada driller's license number issued by the Division of Water Resources, the on-site driller
Signed Roger M. Thrall (By driller performing actual drilling on site or contractor)
Date Roger M. Thrall 12/22/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627