WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40079
Permit No.
Basin 3-10

NOTICE OF INTENT NO. 21460

1. OWNER Mike Casey
MAILING ADDRESS 1600 Allen Road, Fallon, NV 89406
ADDRESS AT WELL LOCATION 9290 Marshall Road, Fallon, NV 89406

2. LOCATION NW ¼ SE ¼ Sec. 15 T. 19 N/S R. 27 E. Churchill County
PERMIT NO. , Issued by Water Resources | 007-171-46 Parcel No. | Mike & Claudia Casey Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	22	22
Brown Coarse Sand		22	28	6
Green Clay		28	30	2
Brown Clay		30	43	13
Brown Coarse Sand	X	43	58	15

RECEIVED JAN - 8 1993 STATE ENGINEER'S OFFICE

Date started December 11, 19 92
Date completed December 11, 19 92

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 58 Feet Depth Cased 58 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	58 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	58

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 54 feet to 57 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 58 feet

9. WATER LEVEL
Static water level 35' 9" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling Inc. Contractor
Address P.O. Box 1265 Contractor
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
Signed Doug Parsons By driller performing actual drilling on site or contractor
Date Jan 6, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627