WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 40089
Permit No. 55691
Basin 212-LVAB

NOTICE OF INTENT NO. 11786

1. OWNER ZACHARY LAKIS
MAILING ADDRESS
ADDRESS AT WELL LOCATION ANN + MICHELLE CREST

2. LOCATION NE ¼ NE ¼ Sec. 36 T. 19 N/S R. 59 E. CLARK County
PERMIT NO. 55691 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND + ROCKS		0	10	10
CEMENTED GRAVEL		10	30	20
SANDY CLAY + GRAVEL		30	70	40
CEMENTED GRAVEL		70	550	480
W/ STREAKS OF CLAY				
+ GRAVEL				
LIMESTONE		550	590	40
CEMENTED GRAVEL		590	640	50
W/ STREAKS OF				
SANDSTONE				
CEMENTED GRAVEL		640	785	145

JAN 11 1993
STATE ENGINEER'S OFFICE

RECEIVED
JAN 06 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

DONROWE
Received
MAY 31 1996
LAS VEGAS OFFICE

Date started 12-17 1992
Date completed 12-29 1992

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 785 Feet Depth Cased 785 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	785 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.9	.188	+1	785

Perforations:
Type perforation FACTORY
Size perforation ⅛ x 3
From 705 feet to 725 feet
From 745 feet to 765 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 785 feet

9. WATER LEVEL
Static water level 673 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DESERT DRILLING (Contractor)
Address 6475 GARY AVE (Contractor)
LAS VEGAS, NV 89139
Nevada contractor's license number issued by the State Contractor's Board 34274
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1594
Signed Randall Couch (By driller performing actual drilling on site or contractor)
Date 12-30-92

(Rev. 1-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627