

OFFICE USE ONLY  
 Log No. 40891  
 Permit No. \_\_\_\_\_  
 Basin 89  
 NOTICE OF INTENT NO. 21749

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Clay and Myrna Wadsworth ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 2660 Hiko Ave 5045 Dolores Dr  
Reno, Nv 89512 Parcel 13  
 2. LOCATION SE 1/4 NW 1/4 Sec 4 T 20 N/S R 20 F Washoe County  
 PERMIT NO. 83-440-13 Spanish Springs Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	5	5
Sand and loose rock		5	20	15
Brown clay & D/ G		20	30	10
Clay & decomposed volcanic rock		30	240	210
Decomposed volcanic rock & sands		240	300	60
T.D. 300 feet				

8. WELL CONSTRUCTION  
 Depth Drilled 300 Feet Depth Cased 300 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 Feet To 50 Feet  
10 5/8 Inches  
 From 50 Feet To 300 Feet  
8 1/2 Inches  
 From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 1	300

Perforations:  
 Type perforation Factory  
 Size perforation 3/32 X 3  
 From 260 feet to 280 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 300 feet

9. WATER LEVEL  
 Static water level 100 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc  
 Contractor  
 Address 625 Spice Islands Dr Suite L  
 Contractor  
Sparks, Nv 89431  
 Nevada contractor's license number 15291  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1132-T  
 Division of Water Resources, the on-site driller  
 Signed Roger M Thrall  
 By driller performing actual drilling on site or contractor  
 Date Roger M. Thrall 11/30/92

Date started 11/24/92, 19\_\_\_\_\_  
 Date completed 11/25/92, 19\_\_\_\_\_  
 7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		1

RECEIVED  
 JAN 12 1998  
 STATE ENGINEERING OFFICE