WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40169
Permit No.
Basin 49

NOTICE OF INTENT NO. 17975

1. OWNER ROBERT M. ST. LOUIS
MAILING ADDRESS 3302 BEVERLY CIRCLE
ELKO, NV 89801

ADDRESS AT WELL LOCATION
3302 BEVERLY CIRCLE
ELKO, NV 89801

2. LOCATION SW ¼ NE ¼ Sec. 17 T. 34 N/S R. 55 E. ELKO County
PERMIT NO. (Issued by Water Resources) Parcel No. 3 Subdivision Name BEVERLY SUBDIVISION

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVEL AND CLAY	0	0	100	100
GRAVEL AND SAND	0	100	200	100
GRAVEL AND SAND	1 GPM	200	260	60
GRAVEL AND SAND	10GPM	260	280	20
GRAVEL AND SAND	15GPM	280	310	30

'93 JAN 25 P2:04
STATE ENGINEER'S OFFICE

Date started JANUARY 5, 19 93
Date completed JANUARY 9, 19 93

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 310 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9-7/8 Inches		0 Feet	310 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	SCH 40	(STEEL T&C)	0	280

Perforations:
Type perforation SLOT (STAINLESS, WIRE WOUND)
Size perforation .020"
From 280 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 83
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 83 feet to 310 feet

9. WATER LEVEL
Static water level 203 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UT 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1410
Signed (By driller performing actual drilling on site or contractor)
Date JANUARY 12, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627