WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40127
Permit No.
Basin 87

NOTICE OF INTENT NO. 61271

1. OWNER Hertz - Rent-A-Car
MAILING ADDRESS Terminal Way Reno NV
ADDRESS AT WELL LOCATION Same

2. LOCATION SW ¼ NE ¼ Sec 18 T 19 N/S R 20 E Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG MW-3

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Abandonment - well was pressure grouted in all in one stage using portland type II cement with a 6 gallon per bag mix. We used 3 bags. Displacing the well water to surface. | | | | |

Date started 10/12, 1992
Date completed 10/12, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 5 Inches | 0 Feet | 30 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2 | | Sch. 40 | 0 | 30 |
| | | | | |
| | | | | |

Perforations:
Type perforation factory slot
Size perforation .020
From 20 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 17.5 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Andreson Drilling (Contractor)
Address 1635 Belford RD. (Contractor)
RENO NEV. 89509
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed (By driller performing actual drilling on site or contractor)
Date 1/5/93

RECEIVED JAN 06 1993 STATE ENGINEER

(Rev. 3 91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627