

OFFICE USE ONLY
 Log No. 4013
 Permit No. 91
 Basin 91

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20557

1. OWNER Jerry Ponica ADDRESS AT WELL LOCATION 555 Lot#6 Riverdale Cir
 MAILING ADDRESS 231 South Virginia St. Reno, NV. 89501
 2. LOCATION 20W 1/4 NW 1/4 Sec. 8 T. 19N N/S R. 18E E. Washoe County
 PERMIT NO. 51696 Lot #6 38-691-0412 Riverdale Subdivision Donner Trail Block D
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	2	2
Boulders&Gravels some clays		2	38	36
Brown clay w/some gravels		38	101	63
Soft Zone		101	103	2
Brown volcanic rock		103	187	84
Soft Zone		187	190	3
Brown volcanic rock		190	212	22
Fracture	X	212	213	1
Brown volcanic rock		213	218	5
Gray volcanic rock		218	240	22
Fracture	X	240	247	7
Gray volcanic rock		247	253	6
Green volcanic rock		253	288	35
Gray volcanic rock		288	302	14
Soft Zone	X	302	312	10
Gray volcanic rock		312	328	16
Soft Zone	X	328	336	8
Gray volcanic rock		336	350	14

8. WELL CONSTRUCTION
 Depth Drilled 350 Feet Depth Cased 350 Feet
 HOLE DIAMETER (BIT SIZE)
10 Inches 0 Feet 100 Feet
8 5/8 Inches 100 Feet 275 Feet
6 1/8 Inches 275 Feet 350 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	275
5"OD		.188	260	350

Perforations: Factory Sawn Slot
 Type perforation.....
 Size perforation 3/32 x 3 x 5
 From 217 feet to 227 feet
 From 247 feet to 267 feet
 From 5" liner feet to feet
 From 260 feet to 280 feet
 From 300 feet to 340 feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 350 feet

9. WATER LEVEL
 Static water level 93 feet below land surface
 Artesian flow 30 G.P.M. P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling Inc. Contractor
 Address P.O. Box 12370 Contractor
Reno, NV. 89510
 Nevada contractor's license number 22549 issued by the State Contractor's Board
 Nevada driller's license number 923 issued by the Division of Water Resources, the on-site driller.
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date January 12, 1993

Date started December 14, 1992, 19.....
 Date completed December 23, 1992, 19.....

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
NO TEST			