WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

26663

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40133
Permit No.
Basin 93

NOTICE OF INTENT NO. 21689

1. OWNER Dale Kulm
MAILING ADDRESS 140 Sells Street
Sparks, Nevada

ADDRESS AT WELL LOCATION Delia Drive
Antelope Valley

2. LOCATION SW ¼ SW ¼ Sec. 26 T 22 N/S R 19 E Washoe County
PERMIT NO. N/A (Issued by Water Resources) 079-450-~~1533~~ (Parcel No.) Red Rock Estates #275 page 1 (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
XX Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable XX Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Decomposed granite | | | | |
| with 1' thick clay | | | | |
| layers | | 177 | 219 | |
| Granite | | 219 | 249 | |
| Brown sandy clay | | 249 | 250 | |

'93 JAN 29 P1:15 STATE ENGINEER'S OFFICE

Date started 1-9-93, 19
Date completed 1-20-93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| Approx. | 50 | 240 | 4 |

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 61/8 Inches | | 177 Feet | 250 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4.5 | 9 | .2 | 160 | 250 |

Perforations:
Type perforation Mill Slot
Size perforation 1/8" x 3"
From 210 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 160 feet to 250 feet

9. WATER LEVEL
Static water level 50' feet below land surface
Artesian flow None G.P.M. None P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EMDLCO (Contractor)
Address P.O. Box 8056 (Contractor)
Reno, Nevada 89507

Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources to the on-site driller 1536

Signed [signature] (By driller performing actual drilling on site or contractor)
Date 1-22-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627