WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

CCD

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40138
Permit No.
Basin 8-102

NOTICE OF INTENT NO. 20427

1. OWNER LEA O'Dell
MAILING ADDRESS 3160 Holly ST
SILVER SPRINGS NV 89429

ADDRESS AT WELL LOCATION 3160 Holly St
SILVER SPRINGS NV 89429

2. LOCATION SW ¼ SE ¼ SW ¼ Sec. 4 T. 17 N/S R. 22 E/W Lyon County

PERMIT NO. NA (Issued by Water Resources) | Parcel No. 17-117-03 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILT + SAND		0	37	37
Brown Gummy Clay		37	83	46
Brown Clay Small Gravel and sand,		83	102	19
Course + Fine SAND with Some Clay		102	110	8
Course SAND	✓	110	129	19
Brown Clay Verry Gummy,		129	130	1'

'92 DEC 10 A11:34 STATE Engineer

Date started 11/13, 19 92
Date completed 11/17, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air Developed 3½ Hr.			
At OVER 100 GPM.			

8. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	130' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	188	+1	130

Perforations:
Type perforation Torch Cut
Size perforation 3/16 x 5" x 6 Rows
From feet to feet
From 110' feet to 130' feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55 feet to 130' feet

9. WATER LEVEL
Static water level 53 feet below land surface
Artesian flow NA G.P.M. 100+ P.S.I.
Water temperature Cold °F Quality Clean

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling INC. (Contractor)
Address Po. Box 599 (Contractor)
SILVER SPRINGS NV. 89429
Nevada contractor's license number issued by the State Contractor's Board 003184
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 12/9/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627