WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40143
Permit No.
Basin 105

NOTICE OF INTENT NO. 22418

1. OWNER Eagle Land Const.
MAILING ADDRESS 1307 Yellow Jacket Gardnerville NV
ADDRESS AT WELL LOCATION 772 Foothills Gardnerville NV

2. LOCATION NE ¼ NW ¼ Sec. 23 T. 12 N/S R. 19 E. Douglas County
PERMIT NO. ____ Issued by Water Resources | 19-280-36 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DG W SANDY BRN CLAY		0	15	15
LGT BRN SAND		15	24	9
DG W SOME SANDY BRN CLAY		24	41	17
DG W SANDY BRN CLAY		41	67	26
DG SOME SANDY BRN CLAY		67	72	5
HARD STRK		72	79	7
DG SOME SANDY BRN CLAY		79	110	31
DG ~~SOME~~ W SANDY BRN CLAY		110	124	14
HARD STRK OXIDIZED		124	130	6
DG W SOME SANDY BRN CLAY	WB	130	165	35
DG W SANDY BRN CLAY	WB	165	180	15

'93 JAN 27 A11:11
RECEIVED
STATE ENGINEERS OFFICE

Date started ~~1-12~~ 1-13, 1993
Date completed 1-22, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+	20'	2½

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		188	0	180

Perforations:
Type perforation TORCH CUT FACTORY SLOTT
Size perforation 3½ X 3/32
From 180 feet to 161 feet
From 161 feet to 139 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 51'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 180 feet to 51 feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow ____ G.P.M. 25+ P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ____ Contractor
Address A & H PUMP CO 5551 Hwy. 50 East Carson City, Nevada 883-0459 Contractor
Nevada contractor's license number issued by the State Contractor's Board ~~[illegible]~~ 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed Jerald W. Rhimell
By driller performing actual drilling on site or contractor
Date 1-22-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627