

OFFICE USE ONLY  
 Log No. 40#1  
 Permit No. \_\_\_\_\_  
 Basin. 105L

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22275

1. OWNER WESTWINDS CONSTRUCTION ADDRESS AT WELL LOCATION 1829 BITTERBRUSH  
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE, NV

2. LOCATION SW 1/4 SW 1/4 Sec. 36 T. 13 N. R. 20 E. DOUGLAS County  
 PERMIT NO. 23-473-27 WILDFLOWER Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	43	43
GRAVEL		43	56	13
SANDY CLAY + GRAVEL		56	64	8
SANDY CLAY		64	79	15
CLAY		79	88	9
SANDY CLAY		88	153	65
SANDY CLAY + GRAVEL		153	228	75
COARSE SAND + GRAVEL		228	237	9
SANDY CLAY + GRAVEL		237	240	3+

8. WELL CONSTRUCTION  
 Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 240 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>240</u>

Perforations:  
 Type perforation FACTORY SLOTTED  
 Size perforation 3 x 3/32  
 From 220 feet to 240 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50' feet to 240 feet

Date started 12/14, 1992  
 Date completed 12/23, 1992

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>—</u>	<u>1</u>

9. WATER LEVEL  
 Static water level 120 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDCO EXPLORATION, INC  
 Contractor  
 Address 7780 CURRY RD.  
FALLON, NV 89406  
 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726  
 Signed Pat J. Mow  
 By driller performing actual drilling on site or contractor  
 Date 12/22/92

'93 JAN 29 P 1:09  
 STATE ENGINEERS OFFICE