

OFFICE USE ONLY  
 Log No. 40149  
 Permit No. \_\_\_\_\_  
 Basin 108

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK.

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21016  
 #20 PENROSE LANE

1. OWNER MICHAEL & GEORGIA TURNER ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. Box 21587  
Carson City, NV 89721  
 2. LOCATION SW 1/4 SW 1/4 Sec 3 T 14 N/S R 25 E LYON County  
 PERMIT NO. 14-212-02 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silty sand		0	14	14
Sand & med. gravel	3-4	14	21	7
Brown sandy rock		21	30	9
Sandy siltstone & grey rock		30	75	45
Sand w/clay seams		75	85	10
Sand & med gravel	35-40	85	126	41

Abandoned existing well which was located 150 ft. from new well. Well was abandoned by perforation perforating casing and pumping neat cement from bottom up. Well was 45 ft. deep

8. WELL CONSTRUCTION  
 Depth Drilled 126 Feet Depth Cased 126 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 126 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.89	.188	+1 1/2	86

Perforations:  
 Type perforation Mill slot  
 Size perforation 1/8 x 3  
 From 86 feet to 126 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 51'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 51 feet to 126 feet

Date started December 10, 1992  
 Date completed December 11, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>35-38</u>		<u>3</u>

9. WATER LEVEL  
 Static water level 26 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature C °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name HACKWORTH DRILLING, INC. Contractor  
 Address P.O. Box 850 Contractor  
Elko, NV 89803  
 Nevada contractor's license number issued by the State Contractor's Board 020582  
 Nevada driller's license number issued by the Division of Water Resources 1654  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 12-22-92

RECEIVED  
 JAN 14 1993  
 STATE ENGINEER'S OFFICE