

Log No. 40178
 Permit No. _____
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10415

1. OWNER DENNY S HELDON ADDRESS AT WELL LOCATION VICKIE ANN + VICKIE ANN LANE
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 SW 1/4 Sec. 12 T. 21 S N/S R. 53 E. NYE County
 PERMIT NO. 44-550-25 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	11	11
CALICHE		11	15	4
CLAY		15	28	13
CALICHE		28	33	5
CLAY		33	57	24
CALICHE		57	62	5
CLAY		62	77	15
CALICHE	W.B	77	80	3
CLAY		80	98	18
CALICHE	W.B	98	102	4
CLAY		102	130	28
CALICHE	WB	130	133	3
CLAY		133	140	7

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation FACTORY SAW CUT
 Size perforation 8 INCH BY 3 INCH
 From 140 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 140 feet to 50 feet

9. WATER LEVEL
 Static water level 55 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING Contractor
 Address HCR 78 BOX 89047 80358 Contractor
PAHRUMP NV. 89041
 Nevada contractor's license number 30880 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1523
 Signed Annie Brown By driller performing actual drilling on site or contractor
 Date 9-8-92

Date started 9-2 1992
 Date completed 9-9 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

RECEIVED
 SEP 14 1992
 Div. of Water Resources
 Branch Office - Las Vegas, NV