



Book

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10512

1. OWNER (Kent & Diana Peterson)
Frank Lotruglio ADDRESS AT WELL LOCATION N/A
 MAILING ADDRESS 5191 Tee Pee Lane
Las Vegas, Nevada 89129
 2. LOCATION NE 1/4 SE 1/4 Sec. 31 T. 19S N/S R. 60 E. Clark County
 PERMIT NO. 53821 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel		0	15	
Cemented Gravel		15	85	
Clay & Gravel		85	450	
Gravel & Water	x	450	460	
Cemented Gravel		460	510	
Gravel & Water	x	510	530	
Cemented Gravel		530	580	
Gravel & Water	x	580	605	

8. WELL CONSTRUCTION
 Depth Drilled 605 Feet Depth Cased 605 Feet
 HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4" Inches	0	55
9 7/8" Inches	55	605

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"	16.94	.188	+1	605

Perforations:
 Type perforation Factory
 Size perforation 3/16 x 8 row
 From 560 feet to 584 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 55
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

RECEIVED

NOV 24 1992

Div. of Water Resources
 DIVISION OF WATER RESOURCES
 LAS VEGAS, NV

9. WATER LEVEL
 Static water level 360 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vernon H. Dimick Contractor
 Address 3035 S. Torrey Pines Contractor
Las Vegas, Nevada 89102
 Nevada contractor's license number 10062
 issued by the State Contractor's Board
 Nevada driller's license number 552
 issued by the Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 11/19/92

Date started 10/26/92, 19____
 Date completed 11/19/92, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)