WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40199
Permit No.
Basin 212

NOTICE OF INTENT NO. 11929

1. OWNER ARCO 1878
MAILING ADDRESS C/o Broadbent & Assoc
833 NEVADA Hwy B.C.

ADDRESS AT WELL LOCATION ARCO 1878
2801 W. WASHINGTON
LAS VEGAS Nevada.

2. LOCATION NE ¼ SW ¼ Sec. 29 T. 20 N/S R. 61 E. CLARK. County

PERMIT NO. 2211 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☑ Other Auger.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy gravel.		0	6	6.
Silty gravel w/clay		6.	9	3
Silt & sand trace gravel.		9	11	2
Caliche.		11	14	3
Silty Sand w/clay		14	19	5
Sandy Silt w/clay		19	21.5	2.5
Caliche		21.5	22.5	1
Silty Sand w/clay		22.5	25	2.5

T.D = 25

RECEIVED
NOV 30 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 11-5, 1992
Date completed 11-6, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	25 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	2 lbs	Sch. 40	0	25

Perforations:
Type perforation factory slotted
Size perforation 0.020
From 5 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-3 / 1-3 Bent.
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 3 feet to 25 feet

9. WATER LEVEL
Static water level 13.28 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Richard LeBlanc
Contractor
Address 4670 S. Polaris Ave
Contractor
LAS Vegas Nevada 89103
Nevada contractor's license number issued by the State Contractor's Board M-1817
Nevada driller's license number issued by the Division of Water Resources, the on-site driller [illegible]
Signed [signature]
By driller performing actual drilling on site or contractor
Date 11-30-92

(Rev. 3 91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627