

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1234567890  
 Permit No. 40204  
 Basin  
 NOTICE OF INTENT NO. 10745

1. OWNER STEVE KRATKIG ADDRESS AT WELL LOCATION STEWART + Los FELIZ  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SW 1/4 NE 1/4 Sec. 35 T 20 N R 62 E CLARK County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

| Material                             | Water Strata | From | To  | Thick-ness |
|--------------------------------------|--------------|------|-----|------------|
| SAND + ROCKS                         |              | 0    | 60  | 60         |
| CMT. GRAVEL w/ ROCKS                 |              | 60   | 110 | 50         |
| CMT GRAVEL w/ SANDY CLAY + GRAVEL    |              | 110  | 150 | 40         |
| CMT. GRAVEL w/ ROCKS.                |              | 150  | 400 | 250        |
| CMT GRAVEL w/ W/COARSE CLAY + GRAVEL |              | 400  | 420 | 20         |

8. WELL CONSTRUCTION  
 Depth Drilled 420 Feet Depth Cased 420 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 12 1/4 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>8 5/8</u>       | <u>16.94</u>        | <u>.188</u>             | <u>+1</u>   | <u>420</u> |

Perforations:  
 Type perforation FACTORY  
 Size perforation 18 x 3  
 From 380 feet to 400 feet  
 From 340 feet to 360 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 420 feet

9. WATER LEVEL  
 Static water level 260' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 11-7, 1992  
 Date completed 11-12, 1992

7. WELL TEST DATA

| TEST METHOD:  | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift |        |                               |              |
|   |        |                               |              |
|   |        |                               |              |
|   |        |                               |              |

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name DESERT DRILLING Contractor  
 Address 6475 GARY AVE  
LAS VEGAS, NV. 89139  
 Nevada contractor's license number issued by the State Contractor's Board 34274  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1594  
 Signed Pymcalle Coe  
 By driller performing actual drilling on site or contractor  
 Date 11-18-92

RECEIVED  
 NOV 24 1992  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV